PRODUCT TYPE E8X

EXAMPLE PART NUMBERING E8XBF/NP/20/050NP

Gland designed for use with Armoured Cables Silicone Seals for flat cables Detachable Clamping for Braid Armour Brass (B) / Stainless Steel (S) Multiple Certification Locknut (material dictated by gland entry thread material) Including IP Washer, Nylon (N) - Fibre (V) - PTFE (H) Including Earth Tag s Including Serrated Washer Quantity per kit NP Nickel Plated Gland shell size 1/2"NPT Male Entry Thread

LOCKNUT	Brass (ACBLN) / Stainless Steel (ACSLN)
EARTH TAG	Brass (ACBET) / Stainless Steel (ACSET)
IP WASHERS	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
SERRATED WASHERS	Stainless Steel (ACSSW)
IP RATING:	IP66 & IP68 (50 metres - 7 Days), Type 4X
OPERATING TEMP:	Silicone Seals -60°C to +180°C
MATERIALS:	Brass or Stainless Steel
PLATING:	Electroless Nickel

Double Compression Gland Designed for use with Armoured Flat Cable

Ex db: Ex eb: Ex nR: Ex ta: IP66: IP68: Class I Div 2: AEx e: AEx ta

PART NUMBERS:





PRODUCT DESCRIPTION

"EBX" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex db sealing and have been tested to IP66 and IP68 to 50 metres. The E8X version is designed to accommodate armoured cables, sealing on the inner and outer sheaths and also incorporates a detachable armour specific clamping system.

COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31 IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529 UL514B, UL1203, UL2225, UL50E, ANSI/UL 60079-0/7, ISA 60079-31

ATFX II 1D 2G Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc

IECEx Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da NEC - USA Class II Division 1, Groups E, F & G Class I Zone 1 AEx e IIC Gb

Class II Zone 20 AEx ta IIIC Da Class III, Enclosure Type 4X

EAC 1Ex d IIC Gb X / 1Ex e IIC Gb X / 2Ex nR IIC Gc X / Ex ta IIIC Da X INMETRO - Brazil Ex db IIC Gb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da

SAC - China Ex d IIC Gb / Ex e IIC Gb

UKRAINE II 2G Ex db IIC Gb / II 2G Ex eb IIC Gb / II 3G Ex nR IIC Gc / II 1D Ex ta IIIC Da

CCoE - India Ex d IIC Gb (Zone 1) Ex e IIC Gb (Zone 2) Ex nR IIC Gc (Zone 2)

ABS Specified ABS Rules

LLOYD'S Ex d IIC Gb / Ex e IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da RMRS Ex d IC / Ex d IIC / Ex e IC / Ex e IIC / Ex ta IIIC

ATEX SIRA 01ATEX1270X & SIRA 09ATEX1221X

IECEX IECEx SIR 05.0020X NEC - USA CSA 2627370

RU C-GB.BH02.B.00693-18 EAC

INMETRO - Brazil NCC 13.2187 X SAC - China NEPSI GY.116 1398X UKRAINE СЦ 18.0321 Х

CCoE - India PESO P365300/2 & P365300/6

ABS 14-LD463991-1-PDA LLOYD'S 10/00056(E1) RMRS 14.02755.315

Gland Size	Entry Thread Size		Metric Thread	Cable Inner Sheath [C] Width Thickness		Cable Outer Sheath [D] Width Thickness			Armour Acceptance	Nominal Protrusion	Dimensions/Weight (Metric Versions)					
	Metric	NPT	Length [B]	Min	Max	Min	Max	Min	Max	Min	Max	Range	Length [L]	Across Flats [A]	Across Corners	Weight (Kgs)
20S	M20 x 1.5	1/2" or 3/4"	16	6.3	11.7	4.0	7.0	7.9	11.7	4.5	7.0	0.10-0.30	63	30.0	33.0	0.212
20R	M20 x 1.5	1/2" or 3/4"	16	8.1	13.5	5.8	6.2	10.7	16.1	5.4	8.3	0.10-0.30	64	30.0	33.0	0.213
20	M20 x 1.5	1/2" or 3/4"	16	10.3	13.5	5.6	9.0	11.0	13.5	4.5	9.0	0.10-0.30	63	30.0	33.0	0.212

- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads Please refer to our "Thread Reference Tables" for specific dimensions.
- · Assembly instructions must be read prior to installation and adhered to in full.
- · Peppers supply products with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.
- Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- · Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order